SIEMENS

Data sheet

3RT2446-1AP60



contactor AC-1, 140 A, 690 V / 40 °C, 3-pole, 220 V AC, 50 Hz / 240 V, 60 Hz, auxiliary contacts: 1 NO + 1 NC, main circuit: box terminal, control and auxiliary circuit: screw terminal, size: S3

product brand name	SIRIUS
product designation	Contactor
product type designation	3RT24
General technical data	
size of contactor	\$3
product extension	
function module for communication	No
auxiliary switch	Yes
power loss [W] for rated value of the current	
at AC in hot operating state	29.4 W
 at AC in hot operating state per pole 	9.8 W
without load current share typical	8.4 W
insulation voltage	
 of main circuit with degree of pollution 3 rated value 	1 000 V
 of auxiliary circuit with degree of pollution 3 rated value 	690 V
surge voltage resistance	
 of main circuit rated value 	8 kV
 of auxiliary circuit rated value 	6 kV
shock resistance at rectangular impulse	
• at AC	10.3g / 5 ms, 6,.g / 10 ms
shock resistance with sine pulse	
• at AC	16.3g / 5 ms, 10.g / 10 ms
mechanical service life (operating cycles)	
 of contactor typical 	10 000 000
 of the contactor with added electronically optimized auxiliary switch block typical 	5 000 000
 of the contactor with added auxiliary switch block typical 	10 000 000
reference code according to IEC 81346-2	Q
Substance Prohibitance (Date)	03/01/2017
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	
during operation	-25 +60 °C
during storage	-55 +80 °C
relative humidity minimum	10 %
relative humidity at 55 °C according to IEC 60068-2-30 maximum	95 %
Main circuit	
number of poles for main current circuit	3
number of NO contacts for main contacts	3
number of NC contacts for main contacts	0


type of voltage for main current circuit	AC
operational current	
• at AC-1	
— up to 690 V at ambient temperature 40 °C rated value	140 A
— up to 690 V at ambient temperature 55 $^\circ \rm C$ rated value	130 A
— up to 690 V at ambient temperature 60 °C rated value	130 A
— up to 1000 V at ambient temperature 40 °C rated value	60 A
— up to 1000 V at ambient temperature 60 °C rated value	60 A
• at AC-3	
— at 400 V rated value	44 A
— at 690 V rated value	44 A
minimum cross-section in main circuit at maximum AC-1 rated value	50 mm²
no-load switching frequency	
• at AC	5 000 1/h
operating frequency at AC-1 maximum	650 1/h
Control circuit/ Control	
type of voltage	AC
type of voltage of the control supply voltage	AC
control supply voltage at AC	
• at 50 Hz rated value	220 V
at 60 Hz rated value	240 V
operating range factor control supply voltage rated value of magnet coil at AC	
• at 50 Hz	0.8 1.1
• at 60 Hz	0.8 1.1
apparent pick-up power of magnet coil at AC	
• at 50 Hz	326 VA
• at 60 Hz	326 VA
inductive power factor with closing power of the coil	
• at 50 Hz	0.62
• at 60 Hz	0.55
apparent holding power of magnet coil at AC	
• at 50 Hz	22 VA
• at 60 Hz	22 VA
inductive power factor with the holding power of the coil	
• at 50 Hz	0.36
• at 60 Hz	0.4
closing delay	
• at AC	13 50 ms
opening delay	
• at AC	10 21 ms
arcing time	10 21 ms
control version of the switch operating mechanism	Standard A1 - A2
Auxiliary circuit	
number of NC contacts for auxiliary contacts	1
attachable	2
instantaneous contact	2
number of NO contacts for auxiliary contacts	1
attachable	2
	2
instantaneous contact	
operational current at AC-12 maximum	10 A
operational current at AC-15	
• at 230 V rated value	6 A
• at 400 V rated value	3 A
• at 500 V rated value	2 A
at 690 V rated value	1 A
operational current at DC-13	


	10.1
at 24 V rated value	10 A
• at 48 V rated value	2 A
• at 60 V rated value	2 A
• at 110 V rated value	1 A
• at 125 V rated value	0.9 A
 at 220 V rated value 	0.3 A
• at 600 V rated value	0.1 A
design of the miniature circuit breaker for short-circuit protection of the auxiliary switch required	gG: 10 A (230 V, 400 A)
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
Short-circuit protection	
product function short circuit protection	No
design of the fuse link	
 for short-circuit protection of the main circuit 	
 — with type of coordination 1 required 	gG: 250 A (690 V,100 kA)
 — with type of assignment 2 required 	gR: 250 A (690 V, 100 kA)
 for short-circuit protection of the auxiliary switch required 	gG: 10 A (500 V, 1 kA)
Installation/ mounting/ dimensions	
mounting position	+/-180° rotation possible on vertical mounting surface; can be tilted forward and backward by +/- 22.5° on vertical mounting surface
fastening method	screw and snap-on mounting onto 35 mm DIN rail according to DIN EN 60715
 side-by-side mounting 	Yes
height	140 mm
width	70 mm
depth	152 mm
required spacing	
with side-by-side mounting	
— forwards	20 mm
— upwards	10 mm
— downwards	10 mm
— at the side	0 mm
for grounded parts	0 mm
- forwards	20 mm
— upwards	10 mm
•	
— at the side	10 mm
— downwards	10 mm
for live parts	
— forwards	20 mm
— upwards	10 mm
— downwards	10 mm
— at the side	10 mm
Connections/ Terminals	
type of electrical connection	
 for main current circuit 	box terminal
 for auxiliary and control circuit 	screw-type terminals
 at contactor for auxiliary contacts 	Screw-type terminals
of magnet coil	Screw-type terminals
type of connectable conductor cross-sections for main contacts	
• solid	2x (2.5 16 mm²)
stranded	2x (2,5 16 mm²), 2x (10 50 mm²), 1x (10 70 mm²)
solid or stranded	2x (2.5 16 mm²), 2x (10 50 mm²), 1x (10 70 mm²)
 finely stranded with core end processing 	2x (2.5 35 mm²), 1x (2.5 50 mm²)
connectable conductor cross-section for main contacts	
• solid	2.5 16 mm²
 solid or stranded 	4 70 mm²
• stranded	6 70 mm ²
 finely stranded with core end processing 	2.5 50 mm ²
connectable conductor cross-section for auxiliary contacts	
solid or stranded	0.5 2.5 mm²
 finely stranded with core end processing 	0.5 2.5 mm ²
type of connectable conductor cross-sections	
1942 of connectable conductor cross-sections	

e for ouvillance	taata					
 for auxiliary con 	tacts	2	$x (0 = 1 = mm^2) 2x (0 = 7)$	$E = 2 E mm^2$		
— solid — solid or str	anded		x (0.5 1.5 mm²), 2x (0.7 x (0.5 1.5 mm²), 2x (0.7			
	nded with core end process		x (0.5 1.5 mm²), 2x (0.7 x (0.5 1.5 mm²), 2x (0.7	,		
-	for auxiliary contacts	-	x (20 16), 2x (18 14)	5 2.5 mm)		
• for Awg cables		2	x (20 10), 2x (10 14)		_	
product function	operating to IEC 60047.4.1					
	ccording to IEC 60947-4-1		és Io			
. ,	operation according to IEC	C 60947-5-1	lo			
proportion of danger		100	0 %			
	d rate according to SN 319		3 %			
	nd rate according to SN 319		0 a			
1508	interval or service life acco		Ua			
protection class IP on the front according to IEC 60529 touch protection on the front according to IEC 60529		EC 60529	IP20			
		C 60529 fi	nger-safe, for vertical cont	act from the front		
rtificates/ approvals						
General Product App	proval					
	(m)	Confirmation	ŝ	KC	гпг	
QE	(m)		(P)		FHI	
CSA	ccc		UL			
EMC	Functional	Declaration of Co	oformity	Test Certificates		
	Safety/Safety of Ma- chinery	Declaration of Co	morning	Test Certificates		
A	Type Examination Cer-		~ ~	Special Test Certific-	Type Test Certific-	
Â	<u>Type Examination Cer-</u> <u>tificate</u>	UK	CE	<u>Special Test Certific-</u> <u>ate</u>	Type Test Certific- ates/Test Report	
RCM		UK CA	C C EG-Konf.			
RCM		UK CA	CE EG-Konf.			
		UK CA	CE EG-Konf.			
RCM		UK CA	CE EG-Konf.			
RCM			CE EG-Konf.			
KCM			C C EG-Konf.			
KCM		Hoyds	CE EG-Konf.			
Marine / Shipping			EG-Konf.			
Marine / Shipping		Hoyds	EG-Konf.			
Marine / Shipping		Hoyds	EG-Konf.			
ABS	tificate	Lloyd's Register URS	PRS			
ABS	tificate	Lloyds Register Lirs	PRS			
ABS	tificate	Lloyd's Register URS	PRS			
ABS	tificate	Lloyd's Register URS	PRS			
ABS	tificate	Lloyd's Register URS	PRS			
other Confirmation	tificate	Lloyd's Register URS	PRS			
ABS	tificate	Lloyd's Register URS	PRS			
ABS other Confirmation rther information Siemens has decided	tificate tificate Railway Vibration and Shock d to exit the Russian mark	Liovcis Liss Dangerous Good Transport Information	DI TANI PRS DI			
ABS other Confirmation rther information Siemens has decided	tificate tificate tificate tificate to exit the Russian mark to exit the Russian mark	Lioveds Liss Dangerous Good Transport Information	DI TANI			
ABS other Confirmation rther information Siemens has decided ttps://press.siemens.of Siemens is working of Please contact your lo	tificate tificate Railway Vibration and Shock to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the state on the	Dangerous Good Transport Information	En contraction if you interview of the second secon		ates/Test Report	
ABS ABS ABS ABS ABS ABS ABS ABS	tificate tificate tificate Railway Vibration and Shock to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the so other than the sanctioned B	Dangerous Good Transport Information	En contraction if you interview of the second secon	ate	ates/Test Report	
ABS ABS ABS ABS ABS ABS ABS ABS	tificate tificate Railway Vibration and Shock to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the softher than the sanctioned B ackaging	Dangerous Good Transport Information ket (see here). e/siemens-wind-down- rent EAC certificates status of validity of the EAEU member states	En contraction if you interview of the second secon	ate	ates/Test Report	
ABS ABS ABS ABS ABS ABS ABS ABS	tificate tificate Railway Vibration and Shock to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the solution the sanctioned be other than the sanctioned be ackaging / siemens.com/cs/ww/en/viological siemens.com/cs/ww/en/viologic	Liss Dangerous Good Transport Information ket (see here). e/siemens-wind-down rent EAC certificates status of validity of the EAEU member states iew/109813875	En contraction if you interview of the second secon	ate	ates/Test Report	
ABS ABS ABS ABS ABS ABS ABS ABS	tificate tificate	Liss Dangerous Good Transport Information ket (see here). e/siemens-wind-down rent EAC certificates status of validity of the EAEU member states iew/109813875	En contraction if you interview of the second secon	ate	ates/Test Report	
ABS ABS ABS ABS ABS ABS ABS ABS	tificate tificate	Loves Us Dangerous Good Transport Information ket (see here). e/siemens-wind-down rent EAC certificates status of validity of the EAEU member states iew/109813875 Brochures,)	en -russian-business - EAC certification if you inf Russia or Belarus).	ate	ates/Test Report	
ABS ABS ABS ABS ABS ABS ABS ABS	tificate tificate	Loves Us Dangerous Good Transport Information ket (see here). e/siemens-wind-down rent EAC certificates status of validity of the EAEU member states iew/109813875 Brochures,)	en -russian-business - EAC certification if you inf Russia or Belarus).	ate	ates/Test Report	
Ther information Confirmation	tificate tificate	Dangerous Good Transport Information ket (see here). e/siemens-wind-down- rent EAC certificates status of validity of the EAEU member states iew/109813875 Brochures,) alog/product?mlfb=3E	erussian-business EAC certification if you int Russia or Belarus).	ate	ates/Test Report	
ABS ABS ABS ABS ABS ABS ABS ABS	tificate tificate	Dangerous Good Transport Information information ket (see here). e/siemens-wind-down- rent EAC certificates status of validity of the EAEU member states iew/109813875 Brochures,) alog/product?mlfb=3E corder/default.aspx?lar acteristics, FAQs,)	erussian-business EAC certification if you int Russia or Belarus).	ate	ates/Test Report	


Characteristic: Tripping characteristics, I²t, Let-through current <u>https://support.industry.siemens.com/cs/ww/en/ps/3RT2446-1AP60/char</u> Further characteristics (e.g. electrical endurance, switching frequency)

http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RT2446-1AP60&objecttype=14&gridview=view1









last modified:

7/21/2023 🖸

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens: 3RT24461AP60